

### **Application**

- Open office ambient lighting for virtually glare free and shadow free illumination.
- Indirect/Direct suspended lighting fixture; Indirect is 70% and direct is 30%.
- The direct component is controlled by 3" wide semi-specular aluminum baffles standard or opaque overlay (by others).
- This unit is designed for LED or T8
- Fixture will also accept T8 LED tubes.
- Designed for low brightness illumination for general office or classroom applications where 85 to 90% efficiency is needed. All reflectors necessary for performance are supplied as standard.

### **Finishes**


- Unpainted/unfinished formed steel housings with center slotted openings.
- Customer to source a local powder coating facilities to paint steel housings and die cast aluminum end caps.
- An internal ballast bracket assembly is included with precoated white steel and shipped as an assembly with lamp holder brackets and adjustable ballast mounting.
- Reflectors are enhanced aluminum for maximum efficiency for direct and indirect control.

### **Features**

- Fixtures are shipped with die cast aluminum joiners for structural integrity and suspension continuity.
- Fixtures are designed to mount on exact 4 foot and 8 foot centers. Joiners will accept stems, single cable, "V" cable, and power cords as supplied by others.
- Architectural ends. This die cast aluminum end comes standard with flat styled configuration. Ends are bolted to the die cast joiners for a complete architectural look.
- Housing can be differentiated by specifying perforations on the bottom sides parallel to the center slot, perforations on the top sides, or both. You design the look that you want to achieve.
- Fixture can be modified to accept daylight and/or motion detectors.
- Fixture is 9-5/8" wide by 3-1/4" high.


### **Optional Features**

- The housings are roll formed which allows custom lengths with predictable results. Units could also be used in a wall mounted version. Please contact factory for any optional feature.
- Custom modifications in the physical specification and color are available for this fixture.



Specifications subject to change without notice.











## Adam Metal Products Company

# Series 950 / 980 Center Slotted Linear 4-foot Assembly Instructions

### 950 / 980 4ft ASSEMBLY HARDWARE LIST (by others)

- (A) 8-32 X 1/4" Long Machine Screw (4 Pcs.)
- (B) 1/4 20 X 3/4" Long Allen Head Screw (4 Pcs.)
- (C) #8 X 1/4" Screw (6 Pcs.)

#### ASSEMBLY INSTRUCTIONS

- 1.) Mount End Cap to Body with (B)
- 2.) Insert Baffle Assembly (Snaps into 3" slots)
- 3.) Install both Side Reflectors with (C)
- 4.) Install Ballast Assembly with (A). NOTE:

Peel off all protective coating on reflectors.

### NOTE:


If running continuous string of bodies, connect bodies together with (B) to each Joiner. At the end of the run mount End Cap.

Make sure each Joiner has a suspension system.

All suspension systems to be supplied by others.

### Warning:

Each Joiner must have a suspension system.



### NOTE:

When attaching the Bodies together for continuous runs use the inside holes on the Joiner.







## Adam Metal Products Company

### Series 950 / 980 Center Slotted Linear 8-foot Assembly Instructions

### 950 / 980 8ft ASSEMBLY

### HARDWARE LIST (by others)

- (A) 8-32 X 1/4" Long Machine Screw (4 Pcs.)
- (B) 1/4 20 X 3/4" Long Allen Head Screw (4 Pcs.)
- (C) #8 X 1/4" Screw (6 Pcs.)

### ASSEMBLY INSTRUCTIONS

- 1.) Mount End Cap to Body with (B)
- 2.) Insert Baffle Assembly (Snaps into 3" slots)
- 3.) Install Side Reflectors with (C)
- 4.) Install Ballast Assembly with (A). NOTE:

Peel off all protective coating on reflectors.

### NOTE:


If running continuous string of bodies, connect bodies together with (B) to each Joiner. At the end of the run mount End Cap.

Make sure each Joiner has a suspension system.

All suspension systems to be supplied by others.

### Warning:

Each Joiner must have a suspension system.










## Adam Metal Products Company

# Series 950 / 980 Center Slotted Linear Ballast Assembly Instructions




#### RECOMMENDED SOCKETS

600V T5/G5 Vossloh Schwabe - 108660 Stucchi - 268 BJB - 26.620.2004.50 Etlin Daniels - FL622-L

600V T8

Vossloh Schwabe - 108331 (RH) Vossloh Schwabe - 108328 (LH)





#### ASSEMBLY INSTRUCTIONS

- 1.) Attach Ballast to the 8-32 Stud provided in the Wire Trough with 8-32 Lock Nut (A).
- 2.) Attach other end of Ballast to the hole provided in the Wire Trough with 8-32 Screw & Lock Nut (A & B).
- 3.) Snap in Lamp Holders to the Bracket.
- 4.) Attach Ballast Cover to Wire Trough (C).
- 5.) Install Center Reflector to back of Trough using the tab and slots provided.

Note: If using 3 Lamps do not use Center Reflector.

3rd Lamp will replace Center Reflector down the center of the Trough.



